

# 3AC., LTD.

## TEST REPORT

### SCOPE OF WORKS

EVALUATION OF AIR FILTER ANTIVIRAL EFFICIENCY PERFORMANCE TEST IN A CONTINUOUS AIR CONDITION

### REPORT NUMBER

RT20E-S0004

### ISSUE DATE

18-MAR-2020

### PAGES

11

### DOCUMENT CONTROL NUMBER

ISTC-QP-FM-25-04 Rev. 0

© 2017 INTERTEK



## TEST REPORT FOR 3AC CO., LTD.

Report No.: RT20E-S0004

Date: 18-MAR-2020

### OBJECTIVE

The purpose of the testing is:

To evaluate the antibacterial efficacy of air filter in a continuous airflow condition.

### HYPOTHESIS

The antiviral air filter can remove more than 99.9 % of the viruses in a continuous airflow condition.

### CONCLUSION

Based on the data collected the Hypothesis is accepted:

The antiviral air filter can remove more than 99.9 % of the viruses in a continuous airflow condition.

Suyeon Park

ENGINEER



Bo Park

REVIEWER



CONDUCTED BY	3AC CO., LTD.
WITNESSED BY	INTERTEK TESTING SERVICES KOREA LTD.
PERIOD OF TEST	24 FEB 2020 ~ 28 FEB 2020
DATE OF ISSUE	18 MAR 2020

*Except where explicitly agreed in writing, all work and services performed by Intertek is subject to our standard Terms and Conditions which can be obtained at our website: <http://www.intertek.com/terms/>. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. This report is made solely on the basis of your instructions and / or information and materials supplied by you and provide no warranty on the tested sample(s) be truly representative of the sample source. The report is not intended to be a recommendation for any particular course of action, you are responsible for acting as you see fit on the basis of the report results. Intertek is under no obligation to refer to or report upon any facts or circumstances which are outside the specific instructions received and accepts no responsibility to any parties whatsoever, following the issue of the report, for any matters arising outside the agreed scope of the works. This report does not discharge or release you from your legal obligations and duties to any other person. You are the only one authorized to permit copying or distribution of this report (and then only in its entirety). Any such third parties to whom this report may be circulated rely on the content of the report solely at their own risk. This report shall not be reproduced, except in full.*

Date: 18-MAR-2020

**PRODUCT INFORMATION :**

PRODUCT : TRI CARE FILTER

**LABORATORY INFORMATION**

NAME	YONSEI UNIVERSITY
ADDRESS	A487, 1st Engineering Building, Yonsei University, 50 Yonsei-ro, Seodaemun-gu, Seoul , Korea
TECHNITION	Dae Hoon Park

**WITNESS INFORMATION**

NAME	INTERTEK TESTING SERVICES KOREA LTD.
ADDRESS	Intertek Testing Services Korea Ltd. 4/F, A-JU Digital Tower, 7, Ahasan-ro 5 -gil, Seongdong-gu, Seoul, Korea
TECHNICAL MANAGER	Suyeon Park
LABORATORY DIRECTOR	Bo Park

## SECTION 1

### INDEX

SECTION NAMES	PAGE
Objective	5
Parameters	5
Sample acquisition	6
Hypothesis	6
Equipment	6
Technical staff	7
Test procedure	8-9
Test result	10
Conclusion	10
Appendix I. Photo of model	11
Appendix II. Test image	11

Date: 18-MAR-2020

**SECTION 2****OBJECTIVE**

The purpose of the testing is:

To evaluate the antiviral efficiency of air filter in a continuous airflow condition.

**SECTION 3****PARAMETERS**

The following parameters are controlled

VALUE	DESCRIPTION	UNITS	METHOD	MU
23±5	Test room temperature	°C	Thermo-hygrometer	± 0.5 °C (Approx. 95 %, k=2)
50±30	Test room humidity	% R.H.	Thermo-hygrometer	± 2.3 % R.H. (Approx. 95 %, k=2)
37±5	Test incubated Temperature	°C	Thermo-hygrometer	± 0.8 °C (Approx. 95 %, k=2)
24	Test incubated time	hrs	Timer	± 1% (Approx. 95%, k=2)
37±5	Shaking incubated Temperature	°C	Thermo-hygrometer	± 0.8 °C (Approx. 95 %, k=2)
24	Shaking incubated Time	hrs	Timer	± 1% (Approx. 95%, k=2)
φ 1cm pieces	Dimension	cm	Ruler	± 0.007 mm (Approx. 95%, k=2)

The following parameters are monitored

VALUE	DESCRIPTION	UNITS	METHOD	MU
23±5	Test room temperature	°C	Thermo-hygrometer	± 0.5 °C (Approx. 95 %, k=2)
50±30	Test room humidity	% R.H.	Thermo-hygrometer	± 2.3 % R.H. (Approx. 95 %, k=2)
37±5	Test incubated Temperature	°C	Thermo-hygrometer	± 0.8 °C (Approx. 95 %, k=2)
24	Test incubated time	hrs	Timer	± 1% (Approx. 95%, k=2)
37±5	Shaking incubated Temperature	°C	Thermo-hygrometer	± 0.8 °C (Approx. 95 %, k=2)
24	Shaking incubated Time	hrs	Timer	± 1% (Approx. 95%, k=2)
φ 1cm pieces	Dimension	cm	Ruler	± 0.007 mm (Approx. 95%, k=2)

Date: 18-MAR-2020

**SECTION 4****SAMPLE ACQUISITION**

Samples prepared by 3AC Co., Ltd.:

Sample #	Description	Serial #	Purchase Location	Date	Condition
1	Tri Care Filter	-	prepared by 3AC	-	Packaged and undamaged

**SECTION 5****HYPOTHESIS**

The antiviral air filter can remove more than 99.9 % of the viruses in a continuous airflow condition.

**SECTION 6****EQUIPMENT LIST**

#	EQUIPMENT DESCRIPTION	MANUFACTURER'S NAME / MODEL # / SERIAL #	CALIBRATION DATE	CALIBRATION DUE	RANGE USED
1	Autoclave	Coretech / CT-DAC 60	-	-	-
2	Incubator	VISION SCIENTIFIC / VS-1203P4S	2020-02-17	2021-02-16	(15 ~ 45) °C
3	Shaking Incubator	SEJONG Plus	2020-02-17	2021-02-16	(15 ~ 45) °C
4	Biological Safety Cabinet #1	KUMKANGENG Inc. / Class II, Type A	2019-12-13	2020-12-12	-
5	Biological Safety Cabinet #2	Customized / Class II, Type A	2019-12-13	2020-12-12	-
6	Thermometer	Testo/435	-	-	(-50 ~ +150) °C
7	Hydrometer	Testo/435	-	-	(0 ~ 100) % R.H.
8	Pipet (1000)	AXYGEN	2020-02-21	2021-02-20	(100 ~ 1000) µL
9	Pipet (200)	AXYGEN	2020-02-21	2021-02-20	(20 ~ 200) µL
10	Deep-freezer	NIHON FREEZER CO.,LTD.	-	-	(-70 ~ -30) °C
11	Water bath	Coretech / HQ-DW11	-	-	-
12	Clean air supply system	CSI Tech	-	-	-
13	Atomizer	TSI/9302	-	-	-
14	Diffusion dryer	CSI Tech	-	-	-

**Note: The equipment measurement uncertainty is stated in the Test Procedure.**

Date: 18-MAR-2020

**SECTION 7****TECHNICAL STAFF**

#	Staff Name	Area of Expertise
1	Dae Hoon Park	Engineer / Yonsei University.
2	Suyeon Park	Technical Manager / Intertek Testing Korea Ltd.
3	Rody Ju	Technical Manager / Intertek Testing Korea Ltd.
4	Bo Park	Laboratory Director / Intertek Testing Korea Ltd.

**Note: Complete training records for staff are available upon request**

Testing was conducted at:

YONSEI UNIVERSITY

A487, 1ST Engineering Building, Yonsei University, 50 Yonsei-ro, Seodaemun-gu, Seoul 120-749, Korea  
Maetan 3-dong, Yeongtong-gu, Suwon-si, Gyeonggi-do, Korea

Witnessed by : Rody Ju, Suyeon Park

Date: 18-MAR-2020

## SECTION 8

### TEST PROCEDURE

#### 1. Preparation of host bacterial solution:

1.1 The bacteriophage MS2 virus (ATCC 15597-B1), and *Escherichia coli* strain C3000 (ATCC 15597) were used as test virus and host bacteria, respectively.

1.2 In order to restore the bacterial cells from the deep-freezer, 10 mL of tryptic soy broth (TSB) was injected into the freeze-dried cells and the mixture was shaken and incubated for 24 h at 37°C in the shaking incubator. (150-200 rpm)

1.3 0.1 mL of incubated bacterial solution was injected into the 10 mL of TSB, and the mixture was used as a host bacterial solution after additional shaking incubation for 6 h at 37°C

\*\*\* Before experiments, all equipment/sample/solution should be auto-claved for 15 min at 121°C.

#### 2. Preparation of virus solution:

2.1 0.1 mL of the freeze-dried MS2 virus was diluted with 50 mL deionized water (DI water), and the solution was used as a virus solution.

#### 3. Filtration of virus particles:

3.1 The virus solution was aerosolized by an atomizer in 2 LPM of compressed clean air from a clean air supply system.

3.2 Aerosolized virus particles entered the test duct, in which a fabricated filter was installed, through a diffusion dryer in order to remove any moisture.

3.3 The aerosolized virus particles were deposited onto an air filter sample for 15 ~ 30 minutes at standard atmospheric conditions and relative humidity.

#### 4. Elution of virus particles:

4.1 Urea-arginine phosphate buffer (U-APB) solution was prepared by adding 0.9 g of urea, 0.4 mL of 0.2 M NaH<sub>2</sub>PO<sub>4</sub>, and 0.5 M L-arginine into 10 mL of DI water.

4.2 The filter sample was placed into the solution for 10 minutes.

#### 5. Incubation of viruses :

5.1 Then 0.1 mL of the solution was dissolved in 0.9 mL of DI water, and the number of plaques in the solution was counted with a single agar layer method.

5.2 0.1 ml of the solution was mixed with 0.3 mL of host bacterial solution and 29 mL of soft tryptic soy agar (TSA) which was maintained at 48 ~ 50 °C in a water bath. Then the mixture was poured into the petri-dish and incubated overnight at 37 °C.



Date: 18-MAR-2020

\*\*\* Before experiments, all equipment/sample/solution should be auto-claved for 15 min at 121°C.

## 6. Calculation

6.1 Plaque forming unit (PFU) counting: After overnight incubation at 37°C, the number of plaques was counted.

Finally, the overall anti-viral efficiency was calculated using the following equation;

$$\text{Percent reduction} = [(a-b)/a] \times 100$$

*Where:*

*a = the plaque number of virus detected after passing through the untreated filter(PFU/ml)*

*b = the plaque number of virus detected after passing through the tri care filter(PFU/ml)*

*\* The preferable counting range on a Soft TSA is 30-300 colonies.*

Date: 18-MAR-2020

**SECTION 9****TEST RESULT**


Repeat #1	PFU/mL			
	1st	2nd	3rd	Average
Untreated Filter	1660	1700	1770	1710
Tri Care Filter	0	0	0	0
% reduction	99.9			

**SECTION 10****Conclusion**

Based on the data collected the Hypothesis are accepted:


The antiviral air filter can remove more than 99.9 % of the viruses in a continuous airflow condition.

**Appendix I. Photo of sample**



<Tri Care Filter>

**Appendix II. Test image**



< Untreated Filter >



< Tri Care Filter >